

TEST REPORT

**WYLE LABORATORIES**

SCIENTIFIC SERVICES & SYSTEMS GROUP  
WESTERN OPERATIONS, NORCO FACILITY


REPORT NO. 58722-5  
OUR JOB NO. ND 58722  
CONTRACT ---  
YOUR P. O. NO. A02011-2

RAYCHEM CORPORATION  
300 Constitution Drive  
Menlo Park, California 92024

26 - Page Report

DATE 21 December 1982

ENVIRONMENTAL QUALIFICATION TEST REPORT  
OF  
RAYCHEM WCSF-050-N SHIM STOCK  
FOR  
RAYCHEM CORPORATION



STATE OF CALIFORNIA }  
COUNTY OF RIVERSIDE } ss. Ray C. Myrick

, being duly sworn,  
deposes and says: That the information contained in this report is the result of  
complete and carefully conducted tests and is to the best of his knowledge true  
and correct in all respects.

*Ray C. Myrick*

SUBSCRIBED and sworn to before me this 26<sup>th</sup> day of December, 19 82

*Catherine C. Kelly*  
Notary Public in and for the County of Riverside, State of California



W-867A

DEPARTMENT DYNAMICS

DEPT. MGR. *James D. Anderson*  
James D. Anderson

TEST ENGINEER *Luther F. Goad*  
Luther F. Goad

REGISTERED PROFESSIONAL ENGINEER *L. Housteau*

DCAS-QAR VERIFICATION

QUALITY ASSURANCE *L. Housteau*  
L. Housteau

## 1.0 SUMMARY

Six specimens of Raychem WCSF-050-N thin wall, nuclear grade tubing were subjected to an environmental qualification type test to demonstrate the functionality of this product when used as a shim to build up the diameters of small wires to a level within the use range of Raychem's other nuclear grade low voltage products. The test was designed to subject the specimens to all service conditions postulated to occur within the containment of nuclear generating stations during the installed life of the product. The qualification program was based upon the methods, procedures and guidelines set forth in IEEE Standards 323-1974<sup>1</sup> and 383-1974<sup>2</sup> as endorsed by USNRC Regulatory Guides 1.89<sup>3</sup> and 1.131<sup>4</sup> respectively.

The test specimens were exposed to a single environmental profile encompassing temperatures up to 228°C (442°F) that enveloped the conditions produced by main steamline break and loss-of-coolant accidents (MSLB/LOCA), in accordance with the simulated environmental profile preferred by NUREG-0588<sup>5</sup> for qualifying equipment located inside containment. A caustic solution was sprayed on the test specimens throughout the environmental exposure to simulate conditions that would occur when containment spray systems actuate. Extremes in power supply voltage ranges were simulated by energizing the test specimens at 1000 V a-c and an induced current of 5 amperes.

The effects of installed life were simulated by the accelerated aging of three test specimens to an equivalent service life in excess of 42 years at 90°C (194°F). Accelerated aging was accomplished via thermal exposure at a rate based upon the Arrhenius data documented in Raychem Report EDR-5046<sup>6</sup>. These specimens were then exposed to gamma radiation at a level to include both the postulated LOCA accident dose and a dose equivalent to an installed assembly

containment exposure integrated over a 40-year period. The remaining three specimens received only the postulated accident radiation dose to simulate beginning of life LOCA/MSLB exposure. The thermally aged and the unaged specimens received in excess of  $2.15 \times 10^8$  rads gamma and  $1.65 \times 10^8$  rads gamma respectively.

Acceptance criterion was established as the specimen's ability to maintain physical integrity and to maintain rated voltage and current during and after the environmental exposure. Margin was demonstrated by the specimen's ability to pass voltage withstand testing at 80 volts per mil based on a wire insulation thickness of 0.015 inches.

Based upon the analysis of the performance of the specimens during this test program, it was concluded that Raychem WCSF-050-N tubing is suitable for use inside the containment of nuclear power generating stations.


The LOCA/MSLB environmental exposure was performed by Wyle Laboratories, Norco, California. Thermal preconditioning of samples was performed at Raychem Corporation, Menlo Park, California. Radiation sample preconditioning was performed at Isomedix Inc., Parsippany, New Jersey.

## 2.0 TEST SPECIMEN

### 2.1 Materials and Construction

2.1.1 Each specimen consisted of a No. 14 AWG wire with 0.030 inch XLPE insulation crimped to a solid No. 20 AWG conductor insulated with Thermofit RT-876 Heat Shrinkable Tubing. This crimped connection was then insulated with the Raychem WCSF-N tubing depicted in Figure 1. All tubing was taken from standard production.

2.1.2 All test specimens were assembled by Raychem personnel in the configuration shown in Figure 1, using Raychem's standard cable preparation and splice assembly procedures. The cables were cleaned with 1,1,1 Trichloroethane prior to splice assembly and the components were installed using a Raychem CV-5000 Thermogun, Model 750, hot air heater.



| Key | Component          | Description   | Applicable Raychem Specification Component Drawing |
|-----|--------------------|---|--|
| W   | 1/c - #14 AWG Wire | Rockbestos XLPE 0.03 inch insulation thickness                      | N/A  |
| J   | WCSF-115-6-N       | Splice Sealing Sleeve   | SCD-37001  |
| G   | WCSF-050-3-N       | Conductor Shim  | SCD-37001  |
| C   | 1/c - #20 AWG Wire | Solid Cu Conductor and 0.015 inch thick Thermofit RT-876 insulation | RT-876   |
|     | Parallel Splice    | 0.31 inches long  | N/A  |

Figure 1. Specimen Construction

2.1.3 In addition to these six specimens, several other types of products were tested in this program. The other constructions are the subject of separate reports. For clarity of data presentation, the seven constructions reported herein are referenced as specimen numbers 1 through 6. These specimen numbers are cross-referenced with actual Raychem specimen identification numbers in Table 1.

### 3.0 TEST PROGRAM

#### 3.1 Test Sequence

In conformance with Section 6.3.2 of IEEE Standard 323-1974<sup>1</sup>, test specimens were neither modified nor altered after assembly and each specimen was used throughout the entire test sequence. The test sequence comprising this qualification type test is listed below:

| <u>Sequence</u> | <u>Test Description</u>          |
|-----------------|----------------------------------|
| 1.              | Functional Tests                 |
| 2.              | Specimen Preconditioning         |
| 3.              | Functional Tests                 |
| 4.              | LOCA/MSLB Environmental Exposure |
| 5.              | Functional Tests                 |

#### 3.2 Functional Test Procedures

Functional tests were repeated three times during the test program as shown in Section 3.1. Prior to the performance of each functional testing cycle, all test specimens were immersed in tap water at room temperature for a minimum of 16 hours. Each splice assembly being tested was submerged 12 or more inches below the water's surface during the 16 hour soak. All functional tests were

performed with the specimens immersed in the water bath. Test values are summarized in Table 2. Equipment calibration data is provided in Appendix B.

### 3.2.1 Insulation Resistance (I.R.)

After the 16 hour immersion, while still in the water bath, the I.R. of each specimen was measured. Measurements were made at 500 volts d-c after one minute of electrification. The water bath was used as the ground plane during this test.

### 3.2.2 Voltage Withstand

After the I.R. of each specimen was measured and while still in the water bath, a 1200 volt a-c voltage withstand test was performed on each test specimen in accordance with ICEA S-61-402, 6.11.2<sup>7</sup>. Using the water bath as ground, the voltage was applied to the conductor in each specimen.

## 3.3 Specimen Preconditioning

### 3.3.1 Thermal Aging

Three specimens were thermally aged to simulate a service condition of over 40 years based upon Arrhenius data for Raychem's nuclear grade materials as documented in Raychem Report EDR-5046.<sup>6</sup> These specimens were aged to an equivalent of 42.8 years installed life at 90°C (194°F). t

The remaining three specimens were not thermally aged, simulating the condition of product at the beginning of installed life. All thermal conditioning was accomplished at Raychem Corporation.

Specimens were placed horizontally in a circulating air oven throughout the aging period. Aging times and temperatures used are presented in Table 1.

### 3.3.2 Radiation Aging

The radiation dose determined to represent the gamma exposure to installed assemblies within containment over a 40 year period was  $5.0 \times 10^7$  rads. The postulated accident gamma radiation dose was  $1.5 \times 10^6$  rads.

Thermally aged specimens were exposed both to the postulated accident dose, plus 10 percent margin, and the dose representing 40 years of installed life totaling  $2.15 \times 10^8$  rads gamma. The samples simulating the beginning of installed life received only the postulated accident dose plus 10 percent margin for a total dose of  $1.65 \times 10^8$  rads gamma.

The actual gamma radiation exposures exceeded the required  $2.15 \times 10^8$  rad and  $1.65 \times 10^8$  rad levels. Table 1 depicts the actual air equivalent radiation doses and associated dose rates by specimen number. The radiation source utilized was  $\text{Co}^{60}$  and the Certificate of Radiation is shown in Appendix A.

### 3.3.3 Functional Tests

The functional tests were again performed after specimen preconditioning as described in Section 3.2. Test values are listed in Table 2.

### 3.4 LOCA/MSLB Environmental Exposure

The test specimens were placed horizontally on perforated metal trays inside a pressure vessel. Extension leads were spliced to the test specimens inside the pressure vessel and insulated with Raychem WCSF-N tubing. The extension leads were brought out of the test vessel through penetrations installed in the pressure vessel to allow for electrical connection and monitoring. The specimens were energized at 1.0 kV a-c to ground and carried a current of 5 amperes. Current values were sampled throughout the test and are presented in Table 3. The voltage energization circuit for each test specimen was separately fused at 1/4 amp. A schematic of the energizing circuit is given in Figure 2.





Figure 2. Energizing Circuit Schematic




A chemical spray solution consisting of 0.28 molar  $\text{H}_3\text{BO}_3$  (300 ppm boron), 0.64 molar  $\text{Na}_2\text{S}_2\text{O}_3$ , buffered with NaOH to a pH of 10.5 at 25°C (77°F) was provided in a separate reservoir. This solution was sprayed through two nozzles from the top of the vessel at a rate in excess of 0.15 gpm/ft<sup>2</sup> beginning immediately after the second temperature transient and ending upon completion of the 30-day environmental exposure (actual flow was 34 gpm). The temperatures, pressures, and spray duration throughout the test period are given in Figure 3. Figure 4 depicts a diagram of the pressure vessel used for the environmental exposure.




- NOTES: (1) Problems encountered with test vessel pressure seals necessitated interrupting the test after 9.0 minutes. Test was resumed at the 177°C (350°F) temperature plateau and the chemical spray was initiated.
- (2) Problems encountered with the test specimen extension leads and the test vessel pressure seals necessitated interrupting the test after 5 hours. The test was resumed at the 177°C (350°F) temperature plateau to complete the required exposure at this temperature level.

Figure 3. Temperature and Pressure Profiles for Simulation of LOCA/MSLB Environment



**Auxiliary Equipment**



- Legend:**
- (T<sub>1</sub>) — Thermocouple
  - (P<sub>1</sub>) — Pressure Transducer
  - (C<sub>1</sub>) — Pressure Control Transducer

Figure 4. LOCA/MSLB Pressure Vessel and Auxiliary Equipment

#### 4.0 TEST RESULTS

##### 4.1 Functional Test Results

The results of all voltage withstand tests and insulation resistance measurements are listed in Table 2. Test specimen current loading values during the environmental exposure are presented in Table 3. Only one specimen was energized throughout the environmental exposure. All of the thermally aged specimens failed where the Thermofit RT-876 tubing was exposed to the LOCA/MSLB environment. The electrical activity was sufficient to burn through both the RT-876 tubing and the No. 20 AWG conductor, physically severing the circuit loop at this point. Two of the three remaining test specimens were found to have cracks in the extension leads connecting the specimen to the voltage and current sources, thereby disabling the energizing circuit. All specimens that were not thermally aged passed post LOCA/MSLB exposure functional testing either in the test vessel or outside of the vessel with the faulty specimen leads removed from test. Thermally aged specimens did not have a sufficient length of conductor remaining after failure to allow for specimen energization and test.

##### 4.2 LOCA/MSLB Environment Exposure

The following details of the profile depicted in Figure 5 are noted:

- a. The temperature of 204°C (400°F) was not reached in 10 seconds as proposed in Raychem Test Plan No. NPE-TP-81-03<sup>8</sup>. Attainable rise times were governed by the apparatus selected to encompass the entire scope of the Raychem test plan and precluded meeting the proposed temperature rise time.

However, during the temperature transients, both the peak temperatures and temperature durations exceeded those proposed.

b. Problems encountered with test vessel pressure seals and the test specimen extension leads necessitated interrupting the test after the second temperature transient and again after five hours of specimen exposure at the 177°C (350°F) temperature plateau. During the interruption at the 177°C (350°F) plateau, the specimens were visually inspected.

Specimen numbers 1, 2, and 3 were found to have been severed from the test loop at a point adjacent to the WCSF-050-N tubing under test where the Thermofit RT-876 had been exposed to the LOCA/MSLB environment. These specimens were left in the test vessel for exposure to the remainder of the environmental profile as unenergized specimens. The remaining specimens appeared to be in good condition. Replacement of the vessel penetration seals was required at this point which necessitated replacement of test specimen extension leads. The specimens themselves were not modified or changed in any way. The test was resumed at the 177°C (350°F) temperature plateau to complete the required specimen exposure at this level.

c. The test specimens were exposed to the LOCA/MSLB environment for 31.3 days rather than the 30 days proposed in Raychem Test Plan No. NPE-TP-81-03<sup>8</sup>.

#### 4.3 Post LOCA/MSLB Inspection

At the conclusion of the environmental exposure, the test vessel was flooded with tap water. Test specimen numbers 4, 5, and 6 were then given a voltage withstand test and the insulation resistances were measured. Test values are

listed in Table 2. The vessel was then opened and the cause for two test circuits being unable to hold rated voltage throughout the environmental exposure investigated.

At this point, specimen extension wires were severed inside the vessel and the specimens were removed for examination. The two specimens unable to pass voltage withstand testing were found to have cracks in the wire insulation too close to the specimen to allow immersion in a water bath. Therefore, these specimens were wrapped with a cotton cloth saturated with water as the ground electrode. With the cracked wire insulation excluded from the test, both specimens passed the voltage withstand test and measured high insulation resistance.

Specimen numbers 1, 2, and 3, which were not energized during the LOCA/MSLB exposure, were visually examined. All specimens were found to be intact, evidencing no signs of cracking or spitting.

A summary of these findings is given in Table 4.

## 5.0 CONCLUSION

Six specimens of Raychem WCSF-050-N nuclear grade tubing were subjected to an environmental qualification type test program designed to simulate the service conditions produced by main steamline break and loss-of-coolant accidents (MSLB/LOCA). The test specimens were exposed to the LOCA/MSLB environmental extremes of temperature, humidity, pressure and chemical spray. These test specimens were conditioned to simulate both the beginning of installed life and over 40 years of installed life. They were exposed to LOCA/MSLB levels of radiation to include both accident dose margin and the postulated containment radiation dose integrated over 40 years of installed life.

While only one specimen could be energized throughout the environmental exposure, the cause for the inability to energize the remaining specimens was traced to a breakdown in the primary insulation of the wire in every case. Raychem RT-876 tubing was used as primary insulation over the #20 AWG solid Cu specimen wire at an installed insulation thickness of 0.015 inches. In consideration of the severe environmental exposure, it is reasonable to assume that energizing the specimens at 1000 V a-c with a mean current value of 5.16 amperes overstressed both the conductor and conductor insulation. All specimens maintained their physical integrity throughout the environmental exposure, showing no signs of cracking or splitting. Three specimens passed post environmental exposure voltage withstand testing and measured good insulation resistance, demonstrating the performance margin of the splice configuration. Based upon the ability of the remaining specimens to physically withstand the preconditioning and the LOCA/HELB environment, and with the knowledge that the Raychem WCSF-050-N tubing is a thin wall version of previously qualified nuclear grade tubing, it was concluded that all specimens passed this type test and would pass functional testing had there have been a sufficient length of intact wire remaining to perform the required electrical tests.

Therefore, these results provide reasonable assurance, by type test, that the Raychem WCSF-050-N tubing can perform its intended function of shimming, insulating, and sealing in the most limiting environment in which it is expected to function. It is concluded that WCSF-050-N is suitable for use on Class IE systems within the containment of nuclear power generating stations.

REFERENCES

1. IEEE Standard 323-1974, "IEEE Standard for Qualifying IE Equipment for Nuclear Power Generating Stations."
2. IEEE Standard 383-1974, "IEEE Standard for Type Test of Class IE Electric Cables, Field Splices, and Connections for Nuclear Power Generating Stations."
3. USNRC Regulatory Guide 1.89, "Qualification of Class IE Equipment for Nuclear Power Plants."
4. USNRC Regulatory Guide 1.131, "Qualification Tests of Electric Cables and Field Splices for Light-Water-Cooled Nuclear Power Plants."
5. NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment."
6. EDR-5046, Raychem Report "Analysis of Heat Aging Data on WCSF Material to Determine Pre-Aging Conditions for Nuclear Qualification Testing."
7. ICEA S-61-402, "ICEA/NEMA Standards Publication Thermoplastic-insulated Wire and Cable for the Transmission and Distribution of Electrical Energy."
8. NPE-TP-81-03, "Environmental Qualification Test Plan of Raychem Nuclear Cable Splice Assemblies."



TABLE 1  
TEST SPECIMEN CONDITIONING SUMMARY

| Specimen Number | Raychem I.D. <sup>1</sup> Number | Thermal Aging <sup>4</sup> |          |  | Radiation Aging <sup>3</sup> |                       |
|-----------------|----------------------------------|----------------------------|----------|--|------------------------------|-----------------------|
|                 |                                  | Temperature                | Duration | Installed <sup>2</sup> Life Equivalent | Dose (rads)                  | Rate (rads/hr)        |
| 1.              | 732-1                            | 150°C (302°F)              | 906 hrs. | 42.3 yrs                               | 2.2 x 10 <sup>8</sup>        | 5.7 x 10 <sup>5</sup> |
| 2.              | 732-2                            | 150°C (302°F)              | 906 hrs. | 42.3 yrs                               | 2.2 x 10 <sup>8</sup>        | 5.7 x 10 <sup>5</sup> |
| 3.              | 732-3                            | 150°C (302°F)              | 906 hrs. | 42.3 yrs                               | 2.2 x 10 <sup>8</sup>        | 5.7 x 10 <sup>5</sup> |
| 4.              | 161                              | Unaged                     | -        | Day 1                                  | 1.7 x 10 <sup>8</sup>        | 4.7 x 10 <sup>5</sup> |
| 5.              | 162                              | Unaged                     | -        | Day 1                                  | 1.7 x 10 <sup>8</sup>        | 4.7 x 10 <sup>5</sup> |
| 6.              | 163                              | Unaged                     | -        | Day 1                                  | 1.7 x 10 <sup>8</sup>        | 4.7 x 10 <sup>5</sup> |

Notes: (1) Raychem Specimen Identification Numbers are referred to by adjacent Specimen Numbers throughout this report for clarity and ease of understanding.

(2) Installed Life Equivalents are based upon Arrhenius data documented in Raychem Report EDR-5046<sup>5</sup> for continuous conductor temperature of 90°C (194°F).

(3) All Radiation Aging values listed are air equivalents of gamma radiation from a Co<sup>60</sup> source.

(4) The 906 hour Thermal Aging exceeded the required aging time to simulate 40-year life for the cable.

TA... 2  
SUMMARY OF INSULATION RESISTANCE MEASUREMENTS

| Test Conditions  | Test Specimen Insulation Resistance (ohms) |                       |                       |                   |                   |                      |
|--|--|-----------------------|-----------------------|-------------------|-------------------|----------------------|
|  | 1.   | 2.                    | 3.                    | 4.                | 5.                | 6.                   |
| Temperature (°C) (°F)  |  |                       |                       |                   |                   |                      |
| Ambient  | $5.75 \times 10^{12}$                      | $3.25 \times 10^{12}$ | $3.25 \times 10^{12}$ | $8.0 \times 10^9$ | $1.1 \times 10^9$ | $5.0 \times 10^9$    |
| Functional Tests Before Conditioning (Note 1)                    |  |                       |                       |                   |                   |                      |
| Ambient  | $7.0 \times 10^{11}$                       | $1.0 \times 10^{12}$  | $4.0 \times 10^{11}$  | $5.4 \times 10^9$ | $8.8 \times 10^9$ | $4.0 \times 10^{10}$ |
| Functional Tests After Conditioning (Note 1)                     |  |                       |                       |                   |                   |                      |
| Ambient  |  |                       |                       | $8.4 \times 10^9$ |                   |                      |
| Post LOCA/HELB Functional Tests (Notes 1 and 2)                  |  |                       |                       |                   |                   |                      |
| Ambient  | N/A  | N/A                   | N/A                   | N/A               | $2.4 \times 10^7$ | $4.0 \times 10^{10}$ |
| Samples 5 and 6 removed from vessel and retested (Notes 1 and 3) |  |                       |                       |                   |                   |                      |
| Ambient  |  |                       |                       |                   |                   |                      |

Insulation Resistance of Energized Specimens During LOCA/HELB Exposure

| Eclipse of LOCA/HELB Profile | Temperature (°C) (°F) | Vessel Pressure (psig) | Test Specimen Insulation Resistance (ohms) |                   |
|------------------------------|-----------------------|------------------------|--|-------------------|
|                              |                       |                        | 4.   | 5.                |
| After 9 hours                | 165                   | 325                    | $2.8 \times 10^7$                          | $1.5 \times 10^6$ |
| After 23 hours               | 153                   | 307                    | $3.5 \times 10^7$                          | $1.3 \times 10^6$ |
| After 82 hours               | 138                   | 280                    | $8.4 \times 10^7$                          | (Note 3)          |
| After 132 hours              | 138                   | 280                    | $7.6 \times 10^7$                          |                   |
| After 272 hours              | 111                   | 232                    | $1.3 \times 10^8$                          |                   |
| After 363 hours              | 111                   | 232                    | $1.1 \times 10^8$                          |                   |
| After 454 hours              | 111                   | 232                    | $1.2 \times 10^8$                          |                   |
| After 546 hours              | 111                   | 232                    | $1.1 \times 10^8$                          |                   |
| After 637 hours              | 111                   | 232                    | $9.4 \times 10^7$                          |                   |

- Notes: (1) All specimens listing an insulation resistance value also passed voltage withstand testing at 1200 V a-c per section 3.2.2
- (2) Specimens 1, 2, and 3 were left in the test vessel as unenergized specimens to demonstrate their physical integrity. This was necessitated by damaged specimen leads which prohibited specimen energization without specimen alteration. (Reference Section 4.2.)
- (3) Specimen numbers 5 and 6 could not be energized throughout the environmental exposure due to cracks found in the extension wire insulation. With the faulty wire excluded from test, both specimens passed voltage withstand testing and measured good insulation resistance after the LOCA/HELB environmental exposure.
- (4) Test vessel was externally pressurized with air to maintain a minimum pressure of 28 psig.

TABLE 3  
CURRENT MONITORING OF TEST SAMPLE NO. 4  
DURING LOCA/MSLB ENVIRONMENTAL EXPOSURE

| <u>Test<br/>Conditions</u> | <u>Temperature</u> |             | <u>Vessel<br/>Pressure (psig)</u> | <u>Amperes</u> |
|----------------------------|--------------------|-------------|-----------------------------------|----------------|
|                            | <u>(°C)</u>        | <u>(°F)</u> |                                   |                |
| Pre-LOCA/MSLB (Note 1)     | 85                 | 185         | -                                 | 7              |
| After 3 hours              | 177                | 350         | 120                               | 5              |
| After 26 hours             | 153                | 307         | 51                                | 5              |
| After 2 days               | 138                | 280         | 28                                | 6              |
| After 3 days               | 138                | 280         | 28                                | 5              |
| After 6 days               | 138                | 280         | 28                                | 5              |
| After 8 days               | 111                | 232         | 28 (Note 2)                       | 5              |
| After 9 days               | 111                | 232         | 28                                | 7              |
| After 13 days              | 111                | 232         | 28                                | 5              |
| After 15 days              | 111                | 232         | 28                                | 5              |
| After 17 days              | 111                | 232         | 28                                | 5              |
| After 20 days              | 111                | 232         | 28                                | 7              |
| After 22 days              | 111                | 232         | 28                                | 5              |
| After 24 days              | 111                | 232         | 28                                | 5              |
| After 27 days              | 111                | 232         | 28                                | 3              |
| After 28 days              | 111                | 232         | 28                                | 4              |
| After 29 days              | 111                | 232         | 28                                | 5              |
| After 30 days              | 111                | 232         | 28                                | 3              |
| After 31 days              | 111                | 232         | 28                                | 6              |

Notes: (1) Pre-LOCA/MSLB current measurements were made during test vessel preheat.

(2) Test vessel was externally pressurized with air to maintain a minimum pressure of 28 psig.

Table 4  
Post LOCA/MSLB Inspection Summary

| Specimen Number | Results of Inspection   |
|-----------------|---|
| 1.              | Circuit loop failed during the first five hours of exposure to the LOCA/HELB environment. Failure occurred at the point of exposure of the Thermofit RT-876 tubing adjacent to the WCSF-050-N tubing under test. Specimen remained intact with no signs of splitting or cracking.   |
| 2.              | Circuit loop failed during the first five hours of exposure to the LOCA/HELB environment. Failure occurred at the point of exposure of the Thermofit RT-876 tubing adjacent to the WCSF-050-N tubing under test. Specimen remained intact with no signs of splitting or cracking.   |
| 3.              | Circuit loop failed during the first five hours of exposure to the LOCA/HELB environment. Failure occurred at the point of exposure of the Thermofit RT-876 tubing adjacent to the WCSF-050-N tubing under test. Specimen remained intact with no signs of splitting or cracking.   |
| 4.              | No visible damage to test specimen or wire insulation. Maintained voltage and current throughout environmental exposure. Passed VWT* and measured good insulation resistance while immersed in test vessel.   |
| 5.              | Circuit loop failed between the 9th and 25th hours of exposure to the LOCA/HELB environment. The specimen remained intact showing no signs of splitting or cracking. Cracks were found in the circuit loop wire insulation. Specimen passed VWT* and measured good insulation resistance when removed from vessel and retested. |
| 6.              | Circuit loop failed during the first five hours of exposure to the LOCA/HELB environment. The specimen remained intact showing no signs of splitting or cracking. Cracks were found in the circuit loop wire insulation. Specimen passed VWT* and measured good insulation resistance when removed from vessel and retested.    |

\*VWT - Voltage Withstand Test at 1200 V a-c

APPENDIX A

CERTIFICATION OF RADIATION DOSE



February 18, 1982

Mr. Joe Connolly  
Ray Chem Corporation  
300 Constitution Drive  
Menlo Park, California 94025

Dear Mr. Connolly:

This will summarize parameters pertinent to the irradiation of two (2) containers of cable splice samples, as per your Purchase Order #A07349. Specimens were identified as follows:

Group I - R-24593- 165 megarad box

Group II - R-24591 - 215 megarad box

The specimens in Group I were exposed to a Cobalt 60 gamma source for a period of 362 hours at a nominal dose rate of 0.47 megarads per hour. The calculated dose based on dosimetry is 170 megarads. Halfway through the exposure, the specimens were rotated 180 degrees to give a more uniform dose distribution.

The specimens in Group II were exposed to a Cobalt 60 gamma source for a period of 386 hours at a nominal dose rate of 0.57 megarads per hour. The calculated dose based on dosimetry is 220 megarads. Halfway through the exposure, the specimens were rotated 180 degrees to give a more uniform dose distribution.

Dosimetry was performed using Harwell Red 4034 Perspex dosimeters, utilizing a Bausch and Lomb Model 710 spectrophotometer as the readout instrument. This system is calibrated directly with NBS, with the last readout calibration being September 08, 1981. A copy of the dosimetry correlation report is available upon request.

Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the specimens somewhat, but the temperature did not exceed 130 degrees F, as indicated by previous measurements on an oil solution in the same relative position.

Mr. Joe Connolly

-2-

February 18, 1982

Irradiation for Group I was initiated on December 31, 1981,  
and was completed on January 20, 1982.

Irradiation for Group II was initiated on December 31, 1981  
and was completed on January 22, 1982.

Very truly yours,

ISOMEDIX, INC.



David P. Constantine  
Production Manager

DC/mjb

SPECIMEN CABLE SPLICE ASSEMBLIES JOB NO. 58722  
 CUSTOMER RAYCHEM DATE 1-25-82  
 PART NO. SEE REC. INSP. TEST BY G. ADAIR  
 S/N SEE REC. INSP. WITNESS

TEST: LOCA

WYLE LABORATORIES

| EQUIPMENT           | MANUFACTURER        | MODEL NO.  | RANGE  | WYLE NO. | LAST     | CALIBRATION        |       | ACCY.   |
|---------------------|---------------------|------------|--|----------|----------|--------------------|-------|---------|
|                     |                     |            |  |          |          | DUE                | ACCY. |         |
| VOM                 | BECKMAN             | 330        | VARIOUS  | 8892     | 5-4-81   | 5-2-82             |       | DATA    |
| RECORDER            | KAYE                | DR-2B      | VARIOUS  | 8750     | 1-28-82  | 8-1-82             |       | ± 0.05% |
| DIGITAL THERMOMETER | FLUKE               | 2160A      | -350°F to +752°F                                   | 8401     | 12-7-81  | 6-13-82            |       | ± 2.0°F |
| DIGITAL THERMOMETER | FLUKE               | 2160A      | -350°F to +752°F                                   | 8290     | 1-26-82  | 5-30-82            |       | ± 2.0°F |
| DIGITAL THERMOMETER | FLUKE               | 2160A      | -350°F to +752°F                                   | 8032     | 12-29-81 | 5-2-82             |       | ± 2.0°F |
| A/C D/C HYPOT       | ASSOCIATED RESEARCH | 4045       | 0-5K VOLTS   | 9092     | 12-11-81 | 6-13-82            |       | ± 2%    |
| RECORDER            | HEWLETT PACKARD     | 7132A      | 1-500 mV   | 8674     |          | SYSTEM CALIBRATION |       |         |
| RECORDER            | HEWLETT PACKARD     | 7132A      | 1-500 mV   | 8672     |          | SYSTEM CALIBRATION |       |         |
| VOM                 | BECKMAN             | 330        | VARIOUS  | 8893     | 7-1-81   | 7-4-82             |       | DATA    |
| GAUGE               | ASHCROFT            | 7320       | 0-100 psi  | 4435     | 1-22-82  | 4-25-82            |       | -       |
| X-DUCER             | VALIDYNE            | DP-15      | 0-100 psi  | 19937    | 2-2-82   | 8-1-82             |       | ± 1%    |
| X-DUCER             | VALIDYNE GENERAL    | DP-15      | 0-100 psi  | 32738    | 2-2-82   | 8-1-82             |       | ± 1%    |
| MEGOhmmETER         | RADIO               | 1864       | 100-500V <sup>13</sup><br>0-5 X 10 <sup>13</sup> Ω | 199838   | 12-16-81 | 6-16-82            |       | ± 5%    |
| FLOW GAUGE          | BARTON THERMO ELECT | D4-49053-1 | 0-80" H <sub>2</sub> O                             | 7784     | 1-11-82  | 7-18-82            |       | ± 0.5%  |
| DIGITAL I/C MEIER   | DIGIMITE            |            | 0-400°F<br>0-50 VDC                                | 7890     | 2-2-82   | 6-6-82             |       | LABEL   |
| DMM                 | BECKMAN             | 330        | 0-150 ACA  | 8892     | 5-4-81   | 5-2-82             |       | DATA    |
| CURRENT CLAMP       | BECKMAN             | CI-231     | 0-150 ACA  | 9065     | 10-7-81  | 7-4-82             |       | LABEL   |

W6140 O.A. Approval *RAA* Where applicable, the listed test equipment has been calibrated using standards which are traceable to the National Bureau of Standards. Certificates and reports of all calibrations are retained in the Wyle Laboratories QA files and are available for inspection upon request. SHEET 1 OF 2



